


**OFFICE OF THE DIRECTOR
CAPITAL HOSPITAL, BHUBANESWAR**

Corrigendum No. 10357 /DCHB Dated 14.12.17

**CLARIFICATION/AMENDMENT IN RESPONSE TO THE PRE-BID QUERIES OF THE TENDER FOR
SUPPLY, INSTALLATION, COMMISSIONING, CONFIGURATION & OPERATION OF CCTV
SURVEILLANCE SYSTEM IN CAPITAL HOSPITAL, BHUBANESWAR
FOR THE YEAR 2017-18 & 2018-19**

Sl.	Tender Ref. & Clause No.	Queries raised by the prospective bidders	Clarification /Amendment in response to the queries
1	10067/DCHB Dt. 06 th Dec'2017	Inclusion of products of Alcon & Hikvision manufacture	No Change.
2		Cable brands of D-link & Finolex	Accepted. Bidders are allowed to quote for cable for either D-Link or Finolex only.
3		POE SWITCH Brand of D-Link/CISCO	Accepted. Bidders are allowed to quote for POE SWITCH either D-Link or CISCO only.
4		Bifurcation of Price Bid installation as per Table – B (Separate for Cabling & Installation charge)	Accepted. The revised financial bid for table – B is modified & published in the tender documents.
5		Specification of TV – 32" (Specification No.-9)	HDMI cable is added to the existing specification of LED TV
6		Required On-Line UPS	Accepted. On-Line 1 KVA UPS (Preferred Brand: Numeric / APC / Emerson). Bidders are allowed to quote the online UPS.

The revised tender document is uploaded in the website of Capital Hospital, Bhubaneswar.


Director, 14.12.17
Capital Hospital, Bhubaneswar